

Effect of Ventilation System on Spread and Control of Infections (COVID-19) in Indoor Environments: Based on Current Studies

Mohammad Nourmohammadi¹, Ramezan Mirzaei¹, Ebrahim Taban¹, Saeed Yari²

¹Department of Occupational Health and Safety Engineering, School of Public Health, Social Determinants of Health Research Center, Mashhad University of medical sciences, Iran. ²Department of Occupational Health Engineering, Shahid Beheshti University of Medical Sciences, Tehran, Iran.

Abstract

Transmission of infectious diseases like SARS-COV-2 by ventilation systems has become an international concern. In this study, an attempt was made to assess the role of ventilation systems in spread and control of SARS-COV-2 in indoor environments. The results showed that the ventilation system can play an important role in controlling and spreading infectious diseases in indoors environment air change per hour (ACH) is one of the most effective management and engineering strategy to reduce the risk of infection spread. It can be concluded that ventilation system can reduce and spread the infectious disease in indoor environments.

Keywords: Ventilation system-COVID-19- indoor environments- control of infections

Asian Pac Environ Cancer, 3 (1), 55-58

Submission Date: 07/28/2020 Acceptance Date: 09/18/2020

Introduction

Acute Respiratory Syndrome (SARS) in 2002 [1], and concerns about the Influenza pandemic [2] as well as the COVID-19 pandemic that caused by severe acute respiratory syndrome coronavirus (SARS-CoV-2) at the present, suggest that airborne infectious diseases pose serious health risk to human. Most people spend about 90% of their time at indoor area, such as in buildings, cars, or public transportation, which means we breathe air that we shared with others [3]. The present article describes Effect of Ventilation System on Spread and Control of Infections at indoor environment.

Airborne transmission of infectious agent

The concept of airborne infectious agent was first described by Wells and then by Riley. The Wells–Riley equation was used to evaluate the effect of ventilation, filtration on transmission of infectious agent through droplet nuclei [4]. at this equation Various factors affects the transmission of infection, such as Number of people with infection strength of infectious source, Number of particles produced per minute number of susceptible

people breathing the same air, Respiratory rate of exposed individuals, Exposure time and amount of ventilation in the rooms where the exposure occurs [5].

Transmission of infectious diseases at indoor environments is more than outdoor [6-7] infection spread often occurs by contact, droplet and airborne. Contact transmission occur by handshaking or touching contaminated surfaces(direct) [8] transmission by Droplet may occur by the release of infectious droplets from the mouth by sneezing coughing or talking greater than about 5 μm that settles in a short distance and remain in the air for only a short time whereas airborne transmission may occur by the release of infectious droplet nuclei smaller than about 5 μm [5].

Respiratory droplets ($>5 \mu\text{m}$) also transform to droplet nuclei ($<5 \mu\text{m}$) when the environmental conditions change, which is much smaller and can exist in the ambient air for a long time in the form of airborne. some study declare fecal aerosols can cause SARS-CoV-2 infection [9]. At the beginning of outbreak of the coronavirus was assumed with warming of the air, the prevalence of this

Corresponding Author:

Dr. Mohammad Nourmohammadi

Department of Occupational Health and Safety Engineering, School of Public Health, Social Determinants of Health Research Center, Mashhad University of medical sciences, Iran.

Email: mohammadn1365@gmail.com

disease may decrease, but with the warming of the air in the southern regions and the use of air conditioning, the number of patients in these areas increased rapidly, given that in these areas air conditioning system used and the air inside area recirculated, and when a person coughs or sneezes or talks, the virus spreads and accumulates in indoors, and the concentration of coronavirus increases and transmitted to more people.

The COVID-19 and airborne infection

Prevalence of common cold In a Chinese university, ≥ 6 times in a semester was found to be higher (35% compared to 5%) among students living in dormitories with lower mean ventilation rates (1L/s (person) compared to 5L/s person) [10]. In U.S. retail stores, a self-reported common cold infection rate was lower by 43% in stores where ventilation rate was greater (0.5 ACH compared to 1.2ACH) [11].

Jiayun Lu showed air conditioning system can transform covid 19 virus at restaurant [12] also Y. Li showed the bio-aerosol concentration distribution in the ward assumed to be sufficiently agree with the spatial infection pattern of SARS cases [13-14]. Some infections that are spread through the air such as influenza [15], and Bordetella pertussis [16] respiratory syncytial virus (RSV) [17], as well as non-respiratory infections such as norovirus [18], methicillin-resistant Staphylococcus aureus (MRSA) [19]. In order to reduce the transmission of the virus in the air, EPA and ASHRAE recommends precautions, which include increasing the rate of natural and mechanical ventilation, as well as filtration with HEPA to remove more than 99.97% of all particles [20-21]. Many study showed Inadequate ACH has been associated with increase of infection in clinical and non-clinical environment Increasing of ACH suggested to be an effective management and Engineering strategy to reduce the risk of infection spread [22]. Stockwell et al concluded that the concentration of bio aerosol in ward at hospital that use natural ventilation system was much higher than the wards that use mechanical ventilation. also use of mechanical ventilation system improves indoor air quality and also reduces the risk of infection transmission [23]. Menzies et al studied the association between tuberculin conversion among HCWs and the ventilation rate in patient care areas. They found that the tuberculin conversion among HCWs was agree fairly well with inadequate ventilation rate in general patient rooms and also duration of Work staff [24]. Air conditioning systems also transmit the virus to other parts of the building by recirculating indoor air. For example, infection at non-corona wards of hospital can reveal the role of the air conditioning system. One of the important factors in reducing the concentration of airborne droplet is Air change per hour (ACH) Studies have shown that increasing the number of ACH reduces the risk of respiratory infections [25].

Ventilation as preventive or protective measure

Centers for Disease Control Organization in order to prevent the accumulation of bioaerosols recommend

The rate of air change per hour for the isolated room for coronary patients is 12 times as a standard [26]. World Health Organization (WHO) advice 288 m³ per hour per person for infection control in health care system [27]. Parameters affecting indoor air quality (IAQ) during a pandemic, including Mechanical ventilation, Natural ventilation of the building Heat and energy recycling systems Air duct cleaning Air filtration UV lamp radiation Temperature and humidity Should be considered for control of covid 19 virus [28].

At normal working time, the ACH is selected so that energy consumption is optimal. Because exhaust air has energy and depending on the weather, it is cold or hot. And with increasing air exchange rates, energy consumption will also increase. But in the case of Corona pandemics, air exchange rates should reach a maximum in crowded places such as offices, companies, offices, shopping malls. And fresh air enters the places In a study by Hayashi, they concluded that humidification and ventilation control are very effective in controlling infection, and that air pollution can also affect the severity of the disease [29]. Also Yu et al (2017) revealed that increase in air change rate of indoor environment It can reduce the risk of viral infections [30]. Chau et al concluded that if the LEV system is well designed it can Effectively remove concentrations of bioaerosols and infectious droplets from the HCW respiratory area [22].

Chen Reported that 1716 HCWs have been infected with SARS-CoV-2 and the protection for HCWs in Hubei Province makeshift hospitals is necessary. Personal protective equipment and sufficient resting time as management strategy to protect of staff Therefore, they conclude the ACH in makeshift hospitals should be increased to as high as the system can supply. inadequate ACH in makeshift hospitals increase infection airborne transmission [31]. For control of infectious agent in indoor area, ventilation should be increased to prevent accumulation of bio aerosols, and for high-risk environments such as hospitals, fresh air should be increased to as high as their conditioning system can system can support, which may increase energy consumption if return air used HEPA filters should be used in the return air section.

In conclusion, however, due to the approaching cold season, the indoor temperature conditions should be taken into account and 100 fresh air cannot supply for indoors. An alternative way to do this is to use internal purification systems equipped with HEPA filter and ultraviolet Germicidal Irradiation to reduces the concentration of the virus in the air.

References

1. Zhong N, Zheng B, Li Y, Poon L, Xie Z, Chan K, Li P, Tan S, Chang Q, Xie J, Liu X, Xu J, Li D, Yuen K, Peiris J, Guan Y. Epidemiology and cause of severe acute respiratory syndrome (SARS) in Guangdong, People's Republic of China, in February, 2003. *The Lancet*. 2003 Oct;362(9393):1353-1358. [https://doi.org/10.1016/s0140-6736\(03\)14630-2](https://doi.org/10.1016/s0140-6736(03)14630-2)
2. Van Kerkhove MD, Vandemaele KAH, Shinde V, Jaramillo-

- Gutierrez G, Koukounari A, Donnelly CA, Carlino LO, Owen R, Paterson B, Pelletier L, Vachon J, Gonzalez C, Hongjie Y, Zijian F, Chuang SK, Au A, Buda S, Krause G, Haas W, Bonmarin I, Taniguichi K, Nakajima K, Shobayashi T, Takayama Y, Sunagawa T, Heraud JM, Orelle A, Palacios E, van der Sande MAB, Wielders CCHL, Hunt D, Cutter J, Lee VJ, Thomas J, Santa-Olalla P, Sierra-Moros MJ, Hanshaoworakul W, Ungchusak K, Pebody R, Jain S, Mounts AW. Risk Factors for Severe Outcomes following 2009 Influenza A (H1N1) Infection: A Global Pooled Analysis. *Peiris JSM. PLoS Medicine*. 2011 07 05;8(7):e1001053. <https://doi.org/10.1371/journal.pmed.1001053>
3. Qian H, Zheng X. Ventilation control for airborne transmission of human exhaled bio-aerosols in buildings. *Journal of Thoracic Disease*. 2018 07;10(S9):S2295-S2304. <https://doi.org/10.21037/jtd.2018.01.24>
 4. Nardell EA, Keegan J, Cheney SA, Etkind SC. Airborne Infection: Theoretical Limits of Protection Achievable by Building Ventilation. *American Review of Respiratory Disease*. 1991 08;144(2):302-306. <https://doi.org/10.1164/ajrccm/144.2.302>
 5. Nardell EA. Transmission and Institutional Infection Control of Tuberculosis. *Cold Spring Harbor Perspectives in Medicine*. 2015 08 20;6(2):a018192. <https://doi.org/10.1101/cshperspect.a018192>
 6. Al-Waked R. Effect of Ventilation Strategies on Infection Control Inside Operating Theatres. *Eng Appl Comput Fluid Mech*. 2010;4(1):1-16.
 7. Matose M, Poluta M, Douglas TS. Natural ventilation as a means of airborne tuberculosis infection control in minibus taxis. *South African Journal of Science*. 2019 09 26;115(9/10). <https://doi.org/10.17159/sajs.2019/5737>
 8. Siegel JD, Rhinehart E, Jackson M, Chiarello L. 2007 Guideline for Isolation Precautions: Preventing Transmission of Infectious Agents in Health Care Settings. *American Journal of Infection Control*. 2007 Dec;35(10):S65-S164. <https://doi.org/10.1016/j.ajic.2007.10.007>
 9. Meng X, Huang X, Zhou P, Li C, Wu A. Alert for SARS-CoV-2 infection caused by fecal aerosols in rural areas in China. *Infection Control & Hospital Epidemiology*. 2020 04 07;41(8):987-987. <https://doi.org/10.1017/ice.2020.114>
 10. Sun Y, Wang Z, Zhang Y, Sundell J. In China, Students in Crowded Dormitories with a Low Ventilation Rate Have More Common Colds: Evidence for Airborne Transmission. *Semple MG. PLoS ONE*. 2011 Nov 16;6(11):e27140. <https://doi.org/10.1371/journal.pone.0027140>
 11. Zhou G, Liu H, He M, Yue M, Gong P, Wu F, Li X, Pang Y, Yang X, Ma J, Liu M, Li J, Zhang X. Smoking, leisure-time exercise and frequency of self-reported common cold among the general population in northeastern China: a cross-sectional study. *BMC Public Health*. 2018 02 27;18(1). <https://doi.org/10.1186/s12889-018-5203-5>
 12. Lu J, Gu J, Li K, Xu C, Su W, Lai Z, Zhou D, Yu C, Xu B, Yang Z. COVID-19 Outbreak Associated with Air Conditioning in Restaurant, Guangzhou, China, 2020. *Emerging Infectious Diseases*. 2020 07;26(7):1628-1631. <https://doi.org/10.3201/eid2607.200764>
 13. Li Y, Huang X, Yu ITS, Wong TW, Qian H. Role of air distribution in SARS transmission during the largest nosocomial outbreak in Hong Kong. *Indoor Air*. 2005 04;15(2):83-95. <https://doi.org/10.1111/j.1600-0668.2004.00317.x>
 14. Li Y, Leung GM, Tang JW, Yang X, Chao CYH, Lin JZ, Lu JW, Nielsen PV, Niu J, Qian H, Sleigh AC, Su HJ, Sundell J, Wong TW, Yuen PL. Role of ventilation in airborne transmission of infectious agents in the built environment? a multidisciplinary systematic review. *Indoor Air*. 2007 02;17(1):2-18. <https://doi.org/10.1111/j.1600-0668.2006.00445.x>
 15. Killingley B, Nguyen-Van-Tam J. Routes of influenza transmission. *Influenza and Other Respiratory Viruses*. 2013 08 27;7:42-51. <https://doi.org/10.1111/irv.12080>
 16. Warfel JM, Beren J, Merkel TJ. Airborne Transmission of *Bordetella pertussis*. *Journal of Infectious Diseases*. 2012 07 17;206(6):902-906. <https://doi.org/10.1093/infdis/jis443>
 17. Kulkarni H, Smith CM, Lee DDH, Hirst RA, Easton AJ, O'Callaghan C. Evidence of Respiratory Syncytial Virus Spread by Aerosol. Time to Revisit Infection Control Strategies?. *American Journal of Respiratory and Critical Care Medicine*. 2016 08;194(3):308-316. <https://doi.org/10.1164/rccm.201509-1833oc>
 18. Bonifait L, Charlebois R, Vimont A, Turgeon N, Veillette M, Longtin Y, Jean J, Duchaine C. Detection and Quantification of Airborne Norovirus During Outbreaks in Healthcare Facilities. *Clinical Infectious Diseases*. 2015 04 21;61(3):299-304. <https://doi.org/10.1093/cid/civ321>
 19. Hara S, Yamamoto H, Kawabata A, Azuma T, Ishii S, Okumura N, Ito Y. Airborne transmission from a neonate with Netherton syndrome during an outbreak of MRSA. *Pediatrics International*. 2016 02 22;58(6):518-520. <https://doi.org/10.1111/ped.12841>
 20. [Epa.gov/. coronavirus/indoor-air-and-coronavirus-covid-19..](https://www.epa.gov/coronavirus/indoor-air-and-coronavirus-covid-19)
 21. [Ashrae.org/.technical-resources/residential#intro..](https://www.ashrae.org/technical-resources/residential#intro)
 22. Chau OKY, Liu C, Leung MKH. CFD Analysis of the Performance of a Local Exhaust Ventilation System in a Hospital Ward. *Indoor and Built Environment*. 2006 06;15(3):257-271. <https://doi.org/10.1177/1420326x06066123>
 23. Stockwell R, Ballard E, O'Rourke P, Knibbs L, Morawska L, Bell S. Indoor hospital air and the impact of ventilation on bioaerosols: a systematic review. *Journal of Hospital Infection*. 2019 Oct;103(2):175-184. <https://doi.org/10.1016/j.jhin.2019.06.016>
 24. Menzies D. Hospital Ventilation and Risk for Tuberculous Infection in Canadian Health Care Workers. *Annals of Internal Medicine*. 2000 Nov 21;133(10):779. <https://doi.org/10.7326/0003-4819-133-10-200011210-00010>
 25. Escombe AR, Ticona E, Chávez-Pérez V, Espinoza M, Moore DAJ. Improving natural ventilation in hospital waiting and consulting rooms to reduce nosocomial tuberculosis transmission risk in a low resource setting. *BMC Infectious Diseases*. 2019 01 25;19(1). <https://doi.org/10.1186/s12879-019-3717-9>
 26. CDC. Can Air Conditioning Spread the Coronavirus? Why Experts Are Concerned About Public 2020, 89 Spaces: CDC.
 27. WHO Publication/Guidelines. Natural Ventilation for Infection Control in Health-Care Settings.
 28. Tang J, Li Y, Eames I, Chan P, Ridgway G. Factors involved in the aerosol transmission of infection and control of ventilation in healthcare premises. *Journal of Hospital Infection*. 2006 Oct;64(2):100-114. <https://doi.org/10.1016/j.jhin.2006.05.022>
 29. Hayashi M, Osawa H, Kaihara N. Estimation on humidification and ventilation for infection control in residence for the elderly. 2016; <https://doi.org/10.4225/50/581072F4E88EE>
 30. Yu H, Mui K, Wong L, Chu H. Ventilation of general hospital wards for mitigating infection risks of three kinds of viruses including Middle East respiratory syndrome coronavirus. *Indoor and Built Environment*. 2016 02 13;26(4):514-527. <https://doi.org/10.1177/1420326x16631596>
 31. Chen C, Zhao B. Makeshift hospitals for COVID-19 patients: where health-care workers and patients need sufficient ventilation for more protection. *Journal of Hospital Infection*. 2020 05;105(1):98-99. <https://doi.org/10.1016/j.jhin.2020.05.016>

jhin.2020.03.008



This work is licensed under a Creative Commons Attribution-Non Commercial 4.0 International License.